



Product Service

CERTIFICATE

No. B 085127 0014 Rev. 00

Holder of Certificate: **Wuxi Betteri Electronic Technology Co., LTD**
 5-1, #11, Jinshan Rd. Branch#IV
 Wuxi Optoelectronic Material Science&Technology Park
 214037 Wuxi
 PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

Connector

Installation Couplers for use on AC side of Photovoltaic Sys-tems

Model(s):

BC05C, BC05D

Parameters:

Rated Voltage:	300V AC
Rated Current:	T Main Cable Connector:40A, T Branch Cable Connector:20A For BC05C 40A for BC05D
Class (IEC 61140):	II
Degree of Protection:	IP65/IP68(1m,1h)
Poles Configuration :	L/N/PE
Temperature Range:	-40°C ~+85°C

Tested according to:

PPP 59015A:2013

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704072305003-00
Valid until: 2029-05-30

Date, 2024-06-03

(Yaqu Alex Liu)